

ANTI-VORTEX PLATE

- A. Manufactured by Neptune-Benson. Stainless steel PVC plate shall be " in diameter with " connection for installation on pump suction line within the surge tank.
- B. The plate shall be supported off the floor of the surge tank with 3/4" stainless steel bolts allowing for a minimum 3" gap between the plate and the floor. Hardware shall be included.