

## ASME CONSTRUCTION

- A. Filter tank(s) shall be constructed in accordance with Section VIII, Division 1 of the A.S.M.E. code for unfired pressure vessels, latest edition, and so stamped and certified.
- B. Material selection and thickness shall be based on                      psi operating pressure and  
F design temperature.